

CONDUCTORES DE COBRE

CONDUCTORES DE COBRE



Parte #	AWG	CONFIGURACIÓN DE HILOS	NO. DE HILOS	DIÁMETRO DE HILO	HILO AWG	DIÁMETRO in.(mm)	ESTAÑADO	LBS POR 1000 FT	CIRCULAR MILLS
C50	LP Clase I	Tejido Suave	29	.046"	17	0.338(8.60)	NO	189	61,350
C50T	LP Clase I	Tejido Suave	29	.046"	17	0.338(8.60)	SI	189	61,350
C51	LP Clase I	Tejido Suave	30	.046"	17	0.360(9.16)	NO	191	63,450
C52	#2	Tejido Suave	32	.046"	17	0.382(9.72)	NO	206	67,700
C52T	#2	Tejido Suave	32	.046"	17	0.382(9.72)	SI	206	67,700
C53	#2	Tejido Suave	36	.046"	17	0.393(10.00)	NO	220	76,150
C54	1/0	Tejido Suave	24	.067"	14	0.444(11.30)	NO	340	105,600
C54T	1/0	Tejido Suave	24	.067"	14	0.444(11.30)	SI	340	105,600
C54-19	1/0	Concéntrico	19	.075"	14	0.347(8.82)	NO	325	106,850
C55	LP Clase II	Trenzado cuerda	28	.067"	14	0.472(12.00)	NO	380	125,600
C55T	LP Clase II	Trenzado cuerda	28	.067"	14	0.472(12.00)	SI	380	125,600
C56	2/0	Trenzado cuerda	30	.067"	14	0.495(12.60)	NO	420	134,600
C56T	2/0	Trenzado cuerda	30	.067"	14	0.495(12.60)	SI	420	134,600
C56-19	2/0	Concéntrico	19	.0837"	12	0.403(10.25)	NO	410	133,100
C56-19T	2/0	Concéntrico	19	.0837"	12	0.403(10.25)	SI	410	133,100
C58-19	3/0	Concéntrico	19	.094"	11	0.450(11.45)	NO	518	167,800
C58-19T	3/0	Concéntrico	19	.094"	11	0.450(11.45)	YES	518	167,800
C59-19	4/0	Concéntrico	19	.1057"	10	0.527(13.40)	NO	653	211,600
C59-19T	4/0	Concéntrico	19	.1057"	10	0.527(13.40)	YES	653	211,600
C59-37	4/0	Concéntrico	37	.0757"	13	0.527(13.40)	NO	653	211,600
C59-37T	4/0	Concéntrico	37	.0757"	13	0.527(13.40)	YES	653	211,600



Todos los conductores en esta página son listados UL

